



SOFTWARE RELEASE NOTES

MCS-CONNECT
Version 14.00E
06/17/2013

Updates from previous versions:

New Features:

1. Added support for display of MicroMag states to animated graphics code
2. Added 3 new members to the MachineEeromV14 class.

Bug Fixes:

1. The new Unit, heating and boiler grids data is not being refreshed if the Status/Cooling internal Frame is Iconified. RESOLUTION - Separated out the other internal Frames refresh to test their own Iconified state to determine whether or not to refresh the data.
2. The Boiler Status internal Frame is being created by SW + config combos that do not have them. This is due to the test for this internal Frame and table being incorrect. RESOLUTION - Changed the test to only display the boiler & pumps internal Frame for CHL SW and v11 and v14 cfg types with the boiler bit set.
3. In MicroMagV12Device added a capacity control offset to the Evap target column.
4. In the Alarm Lockout popup for Micro Mag added code to hide columns that contain data that is not relevant to that specific system setup.
5. After downloading new SW into the MicroMag, MCS-Connect is unable to scan and locate the MicroMag until the user disconnects and reconnects. This is due to code meant to talk to the Magnum hanging by sending a message to the microMag which is never answered. Therefore, the FileInputStream never gets closed and we are unable to talk to MicroMag. RESOLUTION - Added a check to skip the extra messages if communicating with a MicroMag.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.